


Appendix I1 Noise Monitoring Results

Project	Works	Date (yyyy-mm-dd)	Station	Weather Condition	Time (hh:mm, 24hour)	Noise Level for 30-min, dB(A)			Limit Level dB(A)	Temp (° C)	Wind Speed (m/s)	Noise Meter Model/ID	Calibrator Model/ID
						Leq	L10	L90					
TMCLKL	HY/2012/07	2014-10-03	NSR1	Sunny	9:19	58	61	56	75	26	0.1	RION NL31 (S/N 00603867)	RION NC73 (S/N 10997142)
TMCLKL	HY/2012/07	2014-10-09	NSR1	Sunny	9:25	59	62	52	75	24	0.2	RION NL31 (S/N 00603867)	RION NC73 (S/N 10997142)
TMCLKL	HY/2012/07	2014-10-15	NSR1	Sunny	10:00	57	60	52	75	22	0.1	RION NL31 (S/N 00603867)	RION NC73 (S/N 10997142)
TMCLKL	HY/2012/07	2014-10-21	NSR1	Sunny	9:36	56	58	52	75	24	0.2	RION NL31 (S/N 00603867)	RION NC73 (S/N 10997142)
TMCLKL	HY/2012/07	2014-10-27	NSR1	Sunny	9:20	56	58	53	75	25	0.2	RION NL31 (S/N 00603867)	RION NC73 (S/N 10997142)
TMCLKL	HY/2012/07	2014-10-30	NSR1	Sunny	9:30	57	60	53	75	25	0.2	RION NL31 (S/N 00603867)	RION NC73 (S/N 10997142)
						Min.	56						
						Max.	59						
						Average	57						

Noise Monitoring Results at NSR 1 ($L_{eq, 30min}$)



Weather condition within the reporting period varied between sunny to rainy.

Major construction works undertaken within the reporting period include Construction of pile cap superstructure of Viaduct B; Channel re-construction at Area 1; Land Piling at Viaducts B, C & D; Construction of pile cap at Viaducts B & D; Additional land GI, trial pits & lab testing; Utility surveys; and Slope work of Slope 9SE-B/C8, 9SE-B/C9 & 9SE-B/F9.

Marine works within the reporting period include Construction of Pile caps at Viaduct B; Marine piling platform installation for Viaducts A, B, C & D; Marine Piling at Viaducts B, C, D & E; and Additional marine ground investigation (GI) and laboratory testing.